



EVALUATION REPORTS
CREATED BY A THIRD PARTY

Date: 8/21/2025

Code pertinent to this approval

8th Edition Florida Building Code (2023), and inclusive of all supplementary documents as of this reports date

Limits of Use

- **Approved for use in HVHZ:** Yes
- **Approved for use outside HVHZ:** Yes
- **Impact Resistant:** Yes
- **Design Pressures:** +75 PSF / -75 PSF
- **Other:** See attached drawings BSE #20-0163 for installation instructions

Model, Number or Name

Series LWC-1000 Aluminum French Door

Description

Large missile impact resistant aluminum French door


Engineering Analysis

- **Comparative Analysis:** No
- **Rational Analysis:** No

Manufacturer Information:

- **Name:** LUXURY WINDOWS CORP.
- **Address:** 5225 NW 36th Ave. Miami FL 33142

MANDATORY TESTS	TEST DESCRIPTION	TESTING FACILITY NAME	TEST REPORT NUMBER / DATE	P.E. THAT SEALED TESTING REPORT
FBC TAS 202 & AAMA/WDMA/CSA 101/I.S.2/A440-22, AAMA 501-24 & FBC TAS 201/203 & ASTM E1886-19/E1996-20	Uniform static pressure test, Air, Water infiltration tests, Large Missile Impact & Cyclic Load	HURRICANE ENGINEERING & TESTING INC.	HETI-25-8144 / June 26th 2024	DR. RAM N. TEWARI, P.E.
FBC TAS 202 & AAMA/WDMA/CSA 101/I.S.2/A440-22, AAMA 501-24 & FBC TAS 201/203 & ASTM E1886-19/1996-20	Uniform static pressure test, Air, Water infiltration tests, Large Missile Impact & Cyclic Load	HURRICANE ENGINEERING & TESTING INC.	HETI-24-8446 / June 26th 2024	DR. RAM N. TEWARI, P.E.
FBC TAS 202 & AAMA/WDMA/CSA 101/I.S.2/A440-22, AAMA 501-24 & FBC TAS 201/203 & ASTM E1886-19/1996-20	Uniform static pressure test, Air, Water infiltration tests, Large Missile Impact & Cyclic Load	HURRICANE ENGINEERING & TESTING INC.	HETI-25-8341 / June 30th 2025	DR. RAM N. TEWARI, P.E.



This item has been digitally signed and sealed by Hugo Llamas, PE, on 8/25/2025. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Hugo Llamas

Digitally signed by Hugo Llamas
Date: 2025.08.25 18:07:55
-04'00'