

PRODUCT EVALUATION REPORT	
Project No. ACE-2024-204	Report No. PER-ACE-1104, Rev. 0

Product Description: Series 76 MD Fixed Window, Impact, HVHZ

Product Manufacturer: ES Windows, Inc., 3550 NW 49th Street, Miami, Florida 33142

Code Compliance Statement: This report evaluates the fenestration product(s) listed above to the requirements of FAC Product Approval Rule 61G20-3. This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone (HVHZ) per the product testing standards listed below.

Compliance Methods: Product Approval Rule 61G20-3.005(1)(a) – Certification Mark or Listing

Documentation/References:

1. Installation Drawing No. SCS-0024, dated 7/12/24, signed and sealed by Robert J. Amoruso, P.E.
2. National Certified Testing Laboratories, 8350 Parkline Blvd., Orlando, FL 32809
 - a. NCTL-210-4097-01, dated 01/02/18, signed and sealed by Douglas J. McDougall, FL PE No. 28392.
 - i. Test Standards
 1. TAS 201-94
 2. TAS 202-94
 3. TAS 203-94
3. Certification – Keystone Certification, Inc.
4. Calculations in support of installation requirements for SCS-0024, signed and sealed by Robert J. Amoruso, PE.
5. Glazing meets the requirements of ASTM E1300-16.

Installation: Fenestration units shall be installed according to installation drawing SCS-0024.

Component Certification and Code Conformance:

- Impact Glazing Interlayer: Kuraray America SentryGlas (SG) per current Miami Dade Notice of Acceptance (N.O.A.) MD N.O.A. SentryGlas (SG) can be found [here](#).

Limitations & Conditions of Use:

- Shall be used in the configurations and product sizes as indicated in SCS-0024.
- This product may be used in the High Velocity Hurricane Zone.
- This product has been tested with impact resistant glazing.
- Site conditions not covered in this product evaluation document are subject to additional engineering analysis by a licensed professional engineer or registered architect as required by the authority having jurisdiction.
- Adequacy of the existing structural substrates as a main wind force resisting system capable of withstanding and transferring applied product loads to the foundation is the responsibility of the licensed professional engineer or registered architect acting as the design professional of record for the project of installation.

PRODUCT EVALUATION REPORT	
Project No. ACE-2024-204	Report No. PER-ACE-1104, Rev. 0

Certificate of Independence per Product
Approval Rule 61G20-3.009

Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E. does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2024.09.22
15:04:21 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752