



EVALUATION REPORTS
CREATED BY A THIRD PARTY

Date: 08/08/2024

Code pertinent to this approval

8th Edition Florida Building Code (2023), and inclusive of all supplementary documents as of this reports date

Limits of Use

- **Approved for use in HVHZ:** Yes
- **Approved for use outside HVHZ:** Yes
- **Impact Resistant:** Yes
- **Design Pressures:** +80 PSF / -80 PSF
- **Other:** See attached drawings #24-0197P.10 for installation instructions

Model, Number or Name

Series FX 100 Aluminum Fixed Window

Description

Series FX 100 Aluminum Fixed Window - L.M.I.


Engineering Analysis

- **Comparative Analysis:** No
- **Rational Analysis:** No

Manufacturer Information:

- **Name:** RC BES WINDOWS LLC
- **Address:** 12900 NW 38th AVE. OPA-LOCKA, FL 33054

MANDATORY TESTS	TEST DESCRIPTION	TESTING FACILITY NAME	TEST REPORT NUMBER / DATE	P.E. THAT SEALED TESTINT REPORT
FBC TAS 202 & AAMA/WDMA/CSA 101/I.S.2/A440-22, AAMA 501-24 & FBC TAS 201/203 & ASTM E1886-19/E1996-20	Uniform static pressure test, Air, Water infiltration tests, Large Missile Impact & Cyclic Load	Fenestration Testing Laboratory, Inc..	FTL-6449/ February 29th 2011	Marlin D. Brinson, P.E.



Digitally signed by Cesar I Soto
Date: 2024.08.15 12:00:33-04'00'

CONTACT: (305) 698-0550 or (786) 877-2699
THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY
CESAR I. SOTO, P.E., ON THE DATE ADJACENT TO THE SEAL.
PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED
SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED
FOR ANY ELECTRONIC COPIES.

08/15/2024
Cesar I. Soto
P.E. #59652, S.I.# 6998627