PARAMOUNT
CONSULTING & ENGINEERING

**EVALUATION REPORTS**

**CREATED BY A THIRD PARTY**

**Date: 08/08/2024**

**Code pertinent to this approval**

8th Edition Florida Building Code (2023), and inclusive of all supplementary documents as of this reports date

**Limits of Use**

- **Approved for use in HVHZ:** Yes
- **Approved for use outside HVHZ:** Yes
- **Impact Resistant:** Yes
- **Design Pressures:** +135 PSF / -135 PSF
- **Other:** See attached drawings #24-0197P.8 for installation instructions

**Model, Number or Name**

Series MHV Aluminum Project Out Window

**Description**

Series MHV Aluminum Project Out Window - S.M.I.

**Engineering Analysis**

- **Comparative Analysis**: No
- **Rational Analysis**: No

**Manufacturer Information:**

- **Name:** RC BES WINDOWS LLC
- **Address:** 12900 NW 38th AVE. OPA-LOCKA, FL 33054

| MANDATORY TESTS | TEST DESCRIPTION | TESTING FACILITY NAME | TEST REPORT NUMBER / DATE | P.E. THAT SEALED TESTINT REPORT |
|---|---|---|---|---|
| FBC TAS 202 & AAMA/WDMA/CSA 101/I.S.2/A440-22, AAMA 501-24 & FBC TAS 201/203 & ASTM E1886-19/E1996-20 | Uniform static pressure test, Air, Water infiltration tests, Forced entry test, Small Missile Impact & Cyclic Load | Fenestration Testing Laboratory, Inc. | FTL-10628/ March 15th 2019 | Idalmis Ortega, P.E. |

CESAR I. SOTO
LICENSE
No. 0059652
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Digitally signed by Cesar I Soto
Date: 2024.08.15 10:57:02-04'00'

CONTACT: (305) 698-0550 or (786) 877-2699
THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY CESAR I. SOTO, P.E., ON THE DATE ADJACENT TO THE SEAL. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

08/15/2024
Cesar I. Soto
P.E. #59652, S.I.# 6998627