AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 46976
Date: 09/02/2026

Detailed Product Description:

Manufacturer: CUSTOM WINDOW SYSTEMS INC.

Manufacturer Address: 1900 SW 44th AVENUE OCALA, FL 34474

Model Name: SERIES 360 ALUMINUM OUTSWING ENTRANCE DOOR

Maximum Load: +100 PSF, -100 PSF (Non- Impact)

Installation Drawings # 21-32F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ___ Yes __X_ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	National Certified Testing Laboratories	10/22/2020	NCTL-210-4179-01	Douglas J. McDougall, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	National Certified Testing Laboratories	10/22/2020	NCTL-210-4179-01	Douglas J. McDougall, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	National Certified Testing Laboratories	10/22/2020	NCTL-210-4179-01	Douglas J. McDougall, P.E.
AAMA 1304	Forced Entry Test	National Certified Testing Laboratories	10/22/2020	NCTL-210-4179-01	Douglas J. McDougall, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ
LICENSE
No. 81223
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Sealed: 9/2/2026