AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

Detailed Product Description: **FL 46985**
Manufacturer: VIWINCO, INC. **Date: 09/25/2026**
Manufacturer Address: 851 HEMLOCK ROAD, MORGANTOWN, PA 19543
Model Name: OCEANVIEW VINYL FIXED WINDOW
Maximum Load: +80.7 PSF, -100 PSF (Non-Impact)
Installation Drawings # 24-47F

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used _X_ Yes ___ No

Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA 101/I.S.2/A440/NAFS)

Test	Description	Test Location	Test Report Date	Test Report #
ASTM E283	Air Infiltration Leakage	Molimo Architectual Testing	5/1/2024	28561.01-106-12
			8/7/2025	31469.01-106-11
			3/23/2026	32483.04-106-12
		Intertek	7/19/2024	R4994.01-109-47
ASTM E331 & ASTM E547	Water Penetration	Architectual Testing	11/13/2007	75595.01-109-47
		Molimo Architectual Testing	5/1/2024	28561.01-106-12
			8/7/2025	31469.01-106-11
			3/23/2026	32483.04-106-12
		Intertek	7/19/2024	R4994.01-109-47
ASTM E330	Uniform Static Air Press.	Architectual Testing	11/13/2007	75595.01-109-47
		Molimo Architectual Testing	5/1/2024	28561.01-106-12
			8/7/2025	31469.01-106-11
			3/23/2026	32483.04-106-12
		Intertek	7/19/2024	R4994.01-109-47
ASTM F588	Forced Entry Test	Molimo Architectual Testing	5/1/2024	28561.01-106-12
			3/23/2026	32483.04-106-12
		Intertek	7/19/2024	R4994.01-109-47

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223

Al-Farooq Corporation EB # 3538

JALAL FAROOQ LICENSE No. 81223 STATE OF FLORIDA PROFESSIONAL ENGINEER

Sealed: 9/25/2026

9360 Sunset Drive STE 220 | Miami, FL 33173 | T: 305.264.8100 | www.afceng.com | alfarooq@afceng.com