

Engineering Evaluation Report - #1630-12062024

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

MI Windows and Doors
650 West Market Street
Gratz, PA 17030
(717) 365-3300

Product Description:

Series 1630 Vinyl Horizontal Roller Window – Large Missile Impact Resistant – FL 47080

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

Approval Document: drawing number 1630HRFPA-LM, signed and sealed by A. Lynn Miller, P.E.

Test Reports:

QAI NOK-0095 QAI Laboratories, Inc, Nokomis, FL, signed and sealed by Idalmis Ortega, P.E.
TAS 201 Large Missile, 202, 203-94

Anchor Calculations signed and sealed by A. Lynn Miller, P.E., dated 10/17/24.

Wood Bucks Anchorage Analysis signed and sealed by A. Lynn Miller, P.E., dated 12/6/2024.

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame and sash material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.

