

Engineering Evaluation Report - #1632-08172026

Prepared by:

A. Lynn Miller, P.E.
3400 Precision Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

MI Windows and Doors
650 West Market Street
Gratz, PA 17030
(717) 365-3300

Product Description:

Series 1632 Vinyl Horizontal Sliding Window – Non-Impact Resistant – FL 47080

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

Approval Document: drawing number 1632HS-NI, signed and sealed by A. Lynn Miller, P.E.
Anchor Calculations signed and sealed by A. Lynn Miller, P.E., dated 08/17/26.

Test Reports:

Report No.: 32959.01-106-12 & 32960.01-106-12, Molimo, LLC, York, PA
Signed by Michael D. Stremmel, P.E.
AAMA/WDMA/CSA 101/I.S.2/A440-22

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-24, refer to approval document for glazing details.
- This product is NOT rated to be used in the HVHZ.
- This product is NOT impact resistant and does require impact protection in wind borne debris regions.
- Frame and sash material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.

