

Evaluation Report FL47094-PID-2300

October 24, 2024

Product Description: 2300 Panel Wall

Manufacturer: Pattison ID (formerly Pattison Sign Group), Knoxville, TN

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing FL47094-PID-2300, signed and sealed by Lucas A. Turner, P.E
- 3) Test Report R0948.01-801-18-r1, from Intertek, with testing performed: TAS 202 Loads, TAS 203 Fatigue Cycle Loading
- 4) Supplemental Calculations to support FL47094-PID-2300, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FL47094-PID-2300.

Limitations of Use: This product:

- May be used up to sizes indicated in FL47094-PID-2300
- Achieves design pressures of +/-75 psf (ASD)
- When installed over a deemed-to-comply wall construction by others in accordance with FBC Sect. 1626.4, is large and small missile impact resistant and does not require the use of shutters.
- May be used in the High Velocity Hurricane Zone
- Requires Alpolic 4mm ACM panel construction with FR core, with 6065-T5 extrusions as indicated in FL47094-PID-2300.
- See FL47094-PID-2300 general notes sheet 1 for additional limitations of use.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Pattison ID or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner, PE
58201
2024.10.24
11:18:03 -05'00'
10/24/2024
Lucas A. Turner, P.E.
FL PE #58201