



ENGINEERING

Rice Engineering, Inc.
105 School Creek Trail | Luxemburg, WI 54217
(P) 920.617.1042 | (F) 920.617.1048

Manufacturer:

Winco Window Co.
6200 Maple Ave.
St. Louis, MO 63130

Product Line:

LMI (E-Missile) 1150S- Awning - FX

Product Description:

Awning Window Mullered to Fixed Window.
Architectural Aluminum Window. The frame is made from 6063-T6 Aluminum.
1-3/16" Insulated glass outboard to inboard, consisting of:
(1/4" HS), (3/8" Air), (3/16" HS / 0.180" SGP / 3/16" HS).

Compliance:

The above product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.006. The product Herein complies with the Florida Building Code 8th Edition (2023).

Documentation:

1. Project Report No: 14-5558
Fenestration Testing Laboratory, Inc.
8148., 74th Avenue Medley, FL
2. Anchor Calculations prepared, signed, and sealed by Wayne Helmila, P.E.
3. Installation Anchorage Drawings for: Snap Trim, Sub-Frame, and F-Clips titled PO-FX Install-E Missile, prepared, signed, and sealed by Wayne Helmila, P.E.

Codes & Limitations:

- | | |
|---|-------------------|
| 1. ASTM E330-14(2021) | +/- 80 psf |
| 2. ASTM E1886-19 | +/- 80 psf |
| 3. ASTM E1996-20 | 9# @ 80 ft/s |
| 4. ASTM E1300-16 | |
| 5. AAMA 450-20 | |
| 6. AAMA 506-16 | |
| 7. Max. window size(s) | 60"x 84", 45"x84" |
| 8. Infill window size(s) | 60"x42", 42"x45" |
| 9. Mullion Span | 84" |
| 10. Max. design pressure | +/- 80 Psf |
| 11. The product <u>is approved</u> for large missile impact protection. | |
| 12. The product <u>is not approved</u> for use in HVHZ zones. | |
| 13. Units must be installed in accordance with manufacturer instructions. | |

Certificate of Independence:

I certify that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Additionally, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com
Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



12/20/2024
COA: 9090

Wayne K Helmila

Digitally signed by Wayne K Helmila
DN: CN=Wayne K Helmila,
dnQualifier=A01410C0000018CDB8F4AFB001A652B,
O=Wisconsin, C=US
Reason: This item has been digitally signed and sealed
by Wayne K. Helmila on the date adjacent to the seal.
Printed copies of this document are not considered
signed and sealed and the signature must be verified
on any electronic copies.
Date: 2024.12.20 16:15:23-06'00'