



PRODUCT EVALUATION REPORT

- Florida Building Code - 8th Edition (2023) -
Per Rule 61G20-3 / Method 1 - D

FL #: 47105.1

DATE: 10/28/2024

Product Description

Manufacturer: NU-VUE INDUSTRIES INC,
Address: 1055 E 29th St, Hialeah, FL 33013
Model Name: NVRTR – Retrofit Strap 14G x 1 ¼"
Maximum Load: Refer to Installation Instructions (JA-1269-24)
Drawing No.: JA-1269-24 dated: 10-25-2024, signed and sealed by Javad Ahmad, PE. FL License No. 70592

This product COMPLIES with the 2023 Florida Building Code - 8th Edition (2023 FBC) and the National Design Specifications for Wood Construction (NDS) 2018, for use in the High-Velocity Hurricane Zone (HVHZ).


Comparative Analysis used: ☐ YES ☒ NO

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	TEST REPORT DATE	TEST SIGNED & SEALED BY
ASTM D1761-20	Test Method for Mechanical Fasteners in Wood and Wood-Based Materials	Hurricane Engineering & Testing Inc. - FL 33178	HETI-24-A939	04/03/2024	Ram N. Tewari, P.E. (No. 46767)
ASTM E8-22	Test Method for Tension Testing of Metallic Materials	Hurricane Engineering & Testing Inc. - FL 33178	HETI-24-A939	04/03/2024	Ram N. Tewari, P.E. (No. 46767)

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code - 8th Edition (2023 FBC).

Evaluation Report Engineer:

Javad Ahmad, PE
FL P.E.# 70592
EB C.A.N. # 34254
JAVAD AHMAD PE, Inc.



Sealed: 10-28-2024

7875 NW 12 Street, Suite 102, Doral, FL 33126