

Evaluation Report FPA-Win-Dor-27_37_250
January 10, 2026

Product Description: 2750 / 250 Standard and 3750 / 250 Premium
Sliding Glass Doors, Non-Impact

Manufacturer: Win-Dor, 450 Delta Ave., Brea, CA 92821

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code, not including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) AAMA/FGIA Certifications as indicated in FL47141
- 3) Approval drawing FPA-Win-Dor-27_37_250, signed and sealed by Lucas A. Turner, P.E.
- 4) Test Reports T24 -020, -060, -072, -081, and -088, by Fenestration Testing Laboratory, Inc., Ranch Cucamonga, CA, and PUS23000087 and PUS23000745.1/.2/.3 by Element Materials Technology, Des Moines, IA, with testing performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-17/22
- 5) Supplemental Calculations to support FPA-Win-Dor-27_37_250, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-Win-Dor-27_37_250.

Limitations of Use: This product:

- May be used in sizes and configurations as indicated in FPA-Win-Dor-27_37_250
- Achieves design pressures as indicated Table 1, Sheet 1, of FPA-Win-Dor-27_37_250
- Is not impact resistant and requires the use of shutters in windborne debris regions
- Requires Vision Extrusion PVC frames with current listing as AAMA 303 Certified Profile Licensee

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Win-Dor or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2026.02.10
15:56:34 -06'00'

2/10/2026
Lucas A. Turner, P.E.
FL PE #58201