



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 47195

Date: 7/16/2025

Detailed Product Description:

Manufacturer: ALDORA ALUMINUM & GLASS PRODUCTS, INC.

Manufacturer Address: 4250 CORAL RIDGE DRIVE, SUITE 101, CORAL SPRINGS, FL 33065

Model Name: VISTA VIEW ALUMINUM SINGLE HUNG WINDOW

Maximum Load: +80 PSF, -140 PSF (Large Missile Impact)

Installation Drawings # 24-101F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	IFET, Inc.	12/10/2024 2/20/2025	TR-IFET-24-0063 TR-IFET-24-0087	Arshad Viqar, P.E. Arshad Viqar, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	IFET, Inc.	12/10/2024 2/20/2025	TR-IFET-24-0063 TR-IFET-24-0087	Arshad Viqar, P.E. Arshad Viqar, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	IFET, Inc.	12/10/2024 2/20/2025	TR-IFET-24-0063 TR-IFET-24-0087	Arshad Viqar, P.E. Arshad Viqar, P.E.
ASTM F588	Forced Entry	IFET, Inc.	12/10/2024 2/20/2025	TR-IFET-24-0063 TR-IFET-24-0087	Arshad Viqar, P.E. Arshad Viqar, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 TAS 201 & 203	Large Missile Impact & Cyclic	IFET, Inc.	12/10/2024 2/20/2025 6/10/2025	TR-IFET-24-0063 TR-IFET-24-0087 TR-IFET-24-0087.RT	Arshad Viqar, P.E. Arshad Viqar, P.E. Arshad Viqar, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 7/21/2025