

Evaluation Report NEO-DAW
January 31, 2025

Product Description: NEO Tilt&Turn and Bipartite Single Leaf Dual Action Window

Manufacturer: Plastixal Sp. Z o.o., Stare Bozejewo 44, 18-430 Wizna, Poland

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code for use outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing NEO-DAW, rev. 0, signed and sealed by Lucas A. Turner, P.E
- 3) Keystone Certification Authorization Reports ID 1453-110 and 111
- 4) Test Reports MLTB-USCA-0109-2023 and MLTB-USCA-0143-2024, from Mobilne Laboratorium
 - a. Testing Performed: AAMA/WDMA/CSA 101/I.S.2/A440-17
- 5) Supplemental Calculations to support NEO-DAW, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document NEO-DAW.

Limitations of Use: This product:

- May be used up to sizes at design pressures as indicated in NEO-DAW
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires reinforced PVC framing as indicated in test reports listed above

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Plastixal or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner, PE
58201
2025.01.31
15:01:54 -06'00'

1/31/2025
Lucas A. Turner, P.E.
FL PE #58201