AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 47256
Date: 1/8/2025

Detailed Product Description:
Manufacturer: CRV Impact Windows and Doors, LLC
Manufacturer Address: 13651 SW 158 PL Miami, FL 33196
Model Name: SERIES 100 ALUMINUM HORIZONTAL ROLLING WINDOW
Maximum Load: +80 PSF, -95 PSF (Large Missile Impact)
Installation Drawings # 25-10F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used _X_ Yes ___ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory, Inc	6/25/2019	FTL-10595	Idalmis Ortega, P.E.
ASTM E331 OR ASTM E547	Water Penetration	Fenestration Testing Laboratory, Inc	6/25/2019	FTL-10595	Idalmis Ortega, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory, Inc	6/25/2019 8/9/2019	FTL-10595 FTL-10829	Idalmis Ortega, P.E.
ASTM F588	Forced Entry Test	Fenestration Testing Laboratory, Inc	6/25/2019	FTL-10595	Idalmis Ortega, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

Test	Description	Test Location	Test Report Date	Test Report#	Test Sealed By
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Fenestration Testing Laboratory, Inc	11/07/2019 6/25/2019 8/9/2019	FTL-10970 FTL-10595 FTL-10829	Idalmis Ortega, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ LICENSE No. 81223 STATE OF FLORIDA PROFESSIONAL ENGINEER

Sealed: 1/20/2025