TURNER
ENGINEERING &
CONSULTING, INC.

2428 Old Natchez Trace Trail
Camden, TN 38320
Ph. 941-380-1574

Evaluation Report NEO-PW
April 29, 2026

Product Description: NEO PVC Fixed Window

Manufacturer: Plastixal Sp. Z o.o., Stare Bożejewo 44, 18-430 Wizna, Poland

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code for use outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
2) Approval drawing NEO-PW, rev. A, signed and sealed by Lucas A. Turner, P.E
3) Keystone Certification Authorization Report ID 1453-119
4) Test Report MLTB-USCA-0267-2026, from Mobilne Laboratorium
    a. Testing Performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-17
5) Supplemental Calculations to support NEO-PW, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document NEO-PW.

Limitations of Use: This product:

- May be used up to sizes at design pressures as indicated in NEO-PW
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires reinforced PVC framing as indicated in test reports listed above

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Plastixal or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

LUCAS A. TURNER
LICENSE
No. 58201
STATE OF
FLORIDA
PROFESSIONAL ENGINEER

Lucas Turner
2026.05.07
10:45:46 -05'00'

4/29/2026
Lucas A. Turner, P.E.
FL PE #58201