

Evaluation Report FPA-MGM-SGD
January 21, 2025

Product Description: Series 9000/9050 Sliding Glass Door

Manufacturer: MGM Industries, Hendersonville, TN

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc. Trl, Camden, TN
- 2) Installation drawing FPA-MGM-SGD, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports 2498.01-109-12, 12044.02-109-12-R1, 29136.02-109-12, and 29156.02-109-12, from Molimo, and H8920.02-501-47, from Intertek, with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-11/17
- 4) Supplemental Calculations to support FPA-MGM-SGD, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to installation drawing FPA-MGM-SGD.

Limitations of Use: This product:

- May be used in the configurations and product sizes as indicated in FPA-MGM-SGD
- Is non-impact and requires the use of impact protective devices in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires rigid PVC extrusions in accordance with Test Report listed above

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in MGM Industries or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner, PE
58201
2025.01.21
10:52:37 -06'00'

1/21/2025
Lucas A. Turner, P.E.
FL PE #58201