

L. Roberto Lomas P.E.

208 7th Ave.

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515512

Manufacturer: **Wojan Window & Door Corporation**
 217 Stover Road
 Charlevoix, MI 49720

Product Line: 4500 Fixed Frame with Louver Non-Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04137, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: C1065.01-602-44 signed by John R. Bordagaray
Architectural Testing, Inc. Schofield, WI.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: 100.25psf
Water penetration resistance: 12.11psf
3. Test report No.: 30832.01-109-122 signed by Joseph E. Allison
Architectural Testing, Inc. Schofield, WI.
ASTM E330
Design pressure: 60.15psf
4. Anchors calculations and comparative analysis, report number 515512-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T6.
- This product was not tested for water infiltration and must be installed only where water penetration resistance is not required.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04137.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

