

Evaluation Report FPA-AM-CA
August 29, 2026

Product Description: Continental and Lineal Design Aluminum Casement Windows

Manufacturer: Air Master Windows and Doors, Barceloneta, P.R. 00617

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing FPA-AM-CA, rev. C, signed and sealed by Lucas A. Turner, P.E
- 3) Test Reports S3040.01-450-18-r2, from Intertek, signed/sealed by Tanya Dolby, P.E., and ATLSF 0604.01-26, from American Test Lab of South Florida, signed/sealed by Stephen Warter, P.E., with testing performed: TAS-201/202/203
- 1) Supplemental Calculations to support FPA-AM-CA, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-AM-CA.

Limitations of Use: This product:

- May be used up to sizes at design pressures as indicated in FPA-AM-CA
- Is large and small missile impact resistant and does not require the use of shutters in windborne debris regions
- May be used in the High Velocity Hurricane Zone
- Requires laminated glass as indicated in FPA-AM-CA using Kuraray Trosifol PVB Interlayer per Miami-Dade N.O.A. #26-0625.05
- Requires 6063-T5 aluminum framing as indicated in FPA-AM-CA

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Air Master Windows and Doors or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2026.09.01
10:50:18 -05'00'

8/29/2026
Lucas A. Turner, P.E.
FL PE #58201