

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: ENDURE LINEAR 900 SERIES POLYMER CEILING PANEL/SOFFIT SYSTEM

MANUFACTURER: RULON INTERNATIONAL
2000 RING WAY
ST. AUGUSTINE, FL 32092

To all concerned,

The Endure Linear 900 Series Polymer Ceiling Panel/Soffit System, manufactured by Rulon International, has been tested per TAS 202, 203, ASTM G155, ASTM D638, ASTM D1929, ASTM E84, and ASTM D635 by Intertek B&C, with results shown in test reports R5753.01-450-18, R5763.02-550-31, and S6159.01-106-18.

Technical Documentation:

1. Drawing "REL-900HZ" dated 5/2/25, signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Intertek B&C, signed and sealed by Tonya Dolby, PE.
3. Supplemental Calculations to support "REL-900HZ", signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all of the requirements of the 8th Edition (2023) Florida Building Code generally, and chapter 15 specifically, including the HVHZ provisions and Miami-Dade Plastics checklist #0445.

Limitations: This System is approved for use inside and outside of the HVHZ as a soffit system only. Please see Drawing REL-900HZ for Max Design Pressures (ASD) and other Limits of Use.


Other Limitations:

1. Fire classification is not a part of this evaluation. Refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Design of substrate is by others and is not a part of this evaluation.
3. Requires Rigid PVC Framing by Rulon International, as tested by Intertek in the reports listed above. I have evaluated this framing material and find that it complies with the requirements of the 8th Edition (2023) Florida Building Code for use in this product.

If you have any questions or need more information concerning this approval, please contact me.

Thank you,


Scott Wolters
FL PE# 62354



Digitally signed
by Scott Wolters
Date: 2025.06.22
11:17:24 -04'00'