

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515438

Manufacturer: Nana Wall Systems, Inc.
100 Meadowcreek Drive, Suite 250
Corte Madera, CA 94925

Product Line: NW Tilt Turn and Fixed Mulled Units

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04097, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Mullion analysis with anchor calculations, report number 515438-1 per AAMA 450 option 3, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to chart in installation drawing
- Mullion span: 120"
- This product is not rated to be used in the HVHZ.
- This product is non-impact resistant and requires impact protection in wind borne debris regions.
- Mullion consists of back-to-back jambs fastened together.
- Fenestration units attached together must have their own separate approval.
- Vertical units may be mulled indefinitely as long as maximum unit size is not exceeded.
- Design pressure of mulled units shall be controlled by the lesser design pressure of the assembly components; the mullion or the individual units.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04097.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

