



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 47571

Date: 06/02/2025

Detailed Product Description:

Manufacturer: ALDORA ALUMINUM & GLASS PRODUCTS INC.

Manufacturer Address: 4250 CORAL RIDGE DRIVE, SUITE 101, CORAL SPRINGS, FL 33065

Model Name: FRONT SET PLUS MONUMENTAL ALUMINUM WINDOW WALL SYSTEM

Maximum Load: +65 PSF, -65 PSF (Large Missile Impact)

Installation Drawings # 25-56F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used ☒ Yes ☐ No					
Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	IFET, Inc.	05/19/2025	IFET-25-0012	Arshad Viqar, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	IFET, Inc.	05/19/2025	IFET-25-0012	Arshad Viqar, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	IFET, Inc.	05/19/2025	IFET-25-0012	Arshad Viqar, PE
ASTM F588	Forced Entry	Blackwater Technical Services, Inc.	03/24/2022 10/03/2024	BT-ALD-21-006 BT-ALD-24-004	Michael Caldwell, PE Michael Caldwell, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 TAS 201 & 203 ASTM E1886/1996 ANSI Z97.1	Large Missile Impact & Cyclic Level D	Blackwater Testing, Inc.	12/15/2015	BT-ALD-15-007	Yamil G. Kuri, PE
		IFET, Inc.	05/19/2025	IFET-25-0012	Arshad Viqar, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538



Sealed: 6/13/2025