BUILDING DROPS
1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of

Hillpointe LLC, dba Proponents LLC
Series ASB-8001 Single Hung Window
(Non-HVHZ) (Non-Impact)

for

Florida Product Approval

FL# FL47645

Report No. 11833

Current Florida Building Code

Method:	**1 – A (Certification Mark or Listing)**
Category:	**Windows**
Sub – Category:	**Single Hung**
Product:	**Series ASB-8001 Single Hung Window**
Materials:	**uPVC**
Product Dimensions:	**See Installation Instructions, HPT003**

Prepared for:
Hillpointe LLC, dba Proponents LLC
8820 Macon Highway, Building 300
Athens, GA 30606

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 9/18/2026

Contents:

Evaluation Report Pages 1 – 3

HERMES F. NORERO LICENSE No. 73778 STATE OF FLORIDA PROFESSIONAL ENGINEER

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.10.09 16:32:24 -04'00'

Hermes F. Norero, P.E.
Florida No. 73778

Manufacturer:	**Hillpointe LLC, dba Proponents LLC**
Product Category:	Windows
Product Sub-Category:	Single Hung
Compliance Method:	State Product Approval Method (1)(a)
Product Name:	**Series ASB-8001 Single Hung Window (Non-HVHZ) (Non-Impact)**

Scope:

This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Hillpointe LLC, dba Proponents LLC** based on Method 1a of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **HPT003**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering.
4. Site conditions that deviate from the details of installation instructions **HPT003** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **HPT003** for size and design pressure limitations.

954.399.8478 954.744.4738
BUILDINGDROPS.COM CONTACT@BUILDINGDROPS.COM

Certification Agency: The manufacturer has demonstrated compliance of manufacture of products in accordance with the Florida Building Code for manufacturing under an approved certification agency through **National Accreditation & Management Institute, Inc.** (FBC Organization # CER1773)

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-17

Referenced Data:

1. Product Testing performed by **Architectural Testing, Inc. (an Intertek company) - Lithia Springs, GA / Atlanta**
   (FBC Organization # TST3892)
   Report #: S3565.01-550-44, Report Date: 05/16/2025

Installation:

Refer to Installation Instructions (**HPT003**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**HPT003**) for design pressures based on size, configuration, and glass types.

954.399.8478 954.744.4738
BUILDINGDROPS.COM CONTACT@BUILDINGDROPS.COM