



En3 Engineering & Consultancy


PRODUCT EVALUATION REPORT

Date: August 20, 2025

Product: **SERIES 351E IMPACT OUTSWING DOOR SYSTEM**
Large Missile Impact Resistant (HVHZ) – Level 'E'

Manufacturer: **Trulite Glass and Aluminum Solutions**
1750 Founders PKWY, Ste. 154
Alpharetta GA, 30009
P (800) 432-8132

Ernesto
Nicolas
Digitally signed
by Ernesto
Nicolas
Date: 2025.08.20
17:59:50 -04'00'



Prepared by: Ernesto Nicolas, P.E. FL #79198

Scope: This report evaluates the above listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005, using Method 1-D (Engineering Evaluation). This product complies with the requirements of the 2023 Florida Building Code 8TH Edition, both inside and outside of the High Velocity Hurricane Zone.

Test Reports:

Tested in accordance with Florida Building Code Test Protocols

Test Laboratory	Report Number	Test Report Date	Test Standard
Intertek	Q7413.01-450-18 R2, signed and sealed by Tanya Dolby, P.E. FL#93536	04/22/25	TAS 202, TAS 201, TAS 203, AAMA1304
Intertek	S6047.01-450-18 R0, signed and sealed by Tanya Dolby, P.E. FL#93536	08/20/25	TAS 202, TAS 201, TAS 203, AAMA1304

Technical Documentation:

- 1) Installation Drawings #25FL-104, Signed and Sealed by Ernesto Nicolas, P.E. (FL# 79198)

Limitations of Use for this product:

- See Installation Drawings #25FL-104 for approved anchor methods and spacing.
- Product is impact rated (Level 'E') and does not require the use of shutters in windborne debris regions.
- May be used inside and outside the High Velocity Hurricane Zone.
- See Installation Drawings #25FL-104 for size and design pressure limitations.
- Site conditions that deviate from the Installation Drawings #25FL-104 require further engineering analysis by a licensed engineer or registered architect.