



Evaluation Report VE-TZFQ-FPA-001

October 16, 2026

Product Description: TZFQ (QPF) Aluminum Fixed Unit Skylight with flexible tube

Manufacturer: VELUX America, LLC. 104 Ben Casey Dr Ft. Mill, SC 29708

Documentation:

1. This evaluation report, prepared by Alan G. Kinne, P.E.
2. Approval drawing VE-TZFQ-FPA-001, signed and sealed by Alan G. Kinne, P.E.
3. NCTL Test Report NCTL-210-4198-01 r1, signed and sealed by Michael Stremmel, P.E.
 - a. TAS 201/202/203
4. Calculations, signed and sealed by Alan G. Kinne, P.E.

Installation: This Product must be installed according to approval drawing VE-TZFQ-FPA-001.

Limitations of Use:

- This product is approved for use at the size and design pressures shown in approval drawing VE-TZFQ-FPA-001. Smaller sizes are also approved.
- This product is approved for use in the High Velocity Hurricane Zone (HVHZ) and is small and large missile impact rated.
- This product does not require the use of shutters in windborne debris regions.
- This product must be glazed per ASTM E1300-16. Refer to approval drawing VE-TZFQ-FPA-001 for glazing details.
- The aluminum frame of this product is 6063-T5 (or better) aluminum.

Statement of Compliance: The product listed within this report was evaluated per the requirements of FAC Product Approval Rule 61G20-3.005 method 1(d). This product complies with the requirements of the 2023 Florida Building Code, 8th Edition and 2026 Florida Building Code, 9th Edition, including the High Velocity Hurricane Zone (HVHZ).

Certification of Independence: I do not have, nor intend to acquire, a financial interest in any company involved in the approval process of the product listed in this product approval. I do not have, nor do I intend to acquire, a financial interest in any other entity involved in the testing of this product.

Kinne Engineering, LLC
523 S Moon Dr
Venice, FL 34292
941-400-6013

