



Date: 06.17.2026

To: JDC Aluminum of Tampa, Inc.
4166 Rice Road
Plant City, FL 33566

Re: Florida Product Approval
Product Category: Panel Walls
Subcategory: Curtainwall
Series/Model: CW251 Aluminum Curtain Wall System (dry glazed)

Submitted Technical Documentation:

1. Test Report 2573T0007 dated 06/05/2024 from PRI Construction Materials Technologies, LLC located in Tampa, FL.
TAS 202-94
AAMA 501-24
ASTM E283: Air Infiltration (6.24 psf)
ASTM E547
ASTM E331: Water Penetration (15 psf)
ASTM E330: Design Pressure (+/-50 psf)
2. Quality Assurance: Keystone Certifications, Inc.

Certification Statement:

According to the information provided in the above-mentioned test report, the CW251 Aluminum Curtain Wall System was tested in accordance with the above referenced standards. Based on the test report and with accepted engineering guidelines to determine the structural capabilities of the system, we certify that the CW251 Aluminum Curtain Wall System fulfills the requirements of the 2023 Florida Building Code Chapter 24.

Compliance:

The above listed products have been shown to demonstrate compliance with the 2023 Florida Building Code and with the Florida Department of Business and Professional Regulation for Statewide Product Approval as per Rule 61G20-3.

Certificate of Independence:

In accordance with Rule 61G20-3, I do not have, nor do I ever intend to acquire, any financial interest in any manufacturing company associated with this evaluation report. I also do not have any financial interest in the manufacturing company or any company associated with the manufacturing company.

Respectfully Submitted,
Cassandra Sharpe, P.E.



06/17/2026