

L. Roberto Lomas P.E.

208 7th Ave.

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515569

Manufacturer: Nana Wall Systems, Inc.
100 Meadowcreek Drive, Suite 250
Corte Madera, CA 94925

Product Line: NW MultiSlide 630 aka EcolineS, Non-Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04173, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: S342.01-301-44 signed by Tyler Westerling P.E.
Intertek, Fresno, CA.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 36.2 psf
Water penetration resistance 6.24psf
3. Anchor calculations and comparative analysis, report number 515569-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be aluminum.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04173.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

