

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515594

Manufacturer: Titoni Windows
155 Arena Street
El Segundo, CA 90245

Product Line: 38 Icon Fixed Window, Non-Impact, HVHZ

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04184, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: S8681.01-303-18 signed and sealed by Tyler Westerling P.E.
Intertek, Lake Forest, CA.
TAS 202 Uniform Static Air Pressure, +70.0/-55.0psf design pressure, 10.65psf water penetration
3. Anchor calculations and comparative analysis, report number 515594-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- Units must be glazed per ASTM E1300.
- This product is rated to be used in the HVHZ.
- This product is non-impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T6

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04184.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

