

**PRODUCT EVALUATION REPORT****- Florida Building Code - 9th Edition (2026) -
Per Rule 61G20-3 / Method 1 - (d)****FL #:** 47930.1**DATE:** 08/20/2026**Product Description**

Manufacturer: E.S. WINDOWS, LLC
Address: 3550 NW 49th St, Miami, FL 33142
Model Name: ES-FX1515AM / ES-SGD1515AM
Maximum Load: +102.0 PSF / -102.0 PSF (Large & Small Missile Impact)
Drawing No.: JA-1909-25, signed and sealed by Javad Ahmad, PE. - FL License No. 70592

This product COMPLIES with the 2026 Florida Building Code - 9th Edition, for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/202/203.

For maximum sizes and anchor type refer to installation drawings.

Comparative Analysis used: ☒ YES ☐ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
ASTM E283/E283M-19	Air Infiltration Leakage	IFET, Inc. - FL 33126	10/27/2025 01/22/2026 01/22/2026 02/16/2026	TR-IFET-25-0052 TR-IFET-25-0052.A TR-IFET-25-0052.B TR-IFET-25-0052.C	Arshad Viqar, P.E. FL PE# 38863
TAS 202-94	Uniform Static Test	IFET, Inc. - FL 33126	10/27/2025 01/22/2026 01/22/2026 02/16/2026	TR-IFET-25-0052 TR-IFET-25-0052.A TR-IFET-25-0052.B TR-IFET-25-0052.C	Arshad Viqar, P.E. FL PE# 38863
ASTM E331-00	Water Penetration by Static Air Pressure Dif.	IFET, Inc. - FL 33126	10/27/2025 01/22/2026 01/22/2026 02/16/2026	TR-IFET-25-0052 TR-IFET-25-0052.A TR-IFET-25-0052.B TR-IFET-25-0052.C	Arshad Viqar, P.E. FL PE# 38863
ASTM F842-17	Forced Entry Resistance of Sliding Door Assemblies, Excluding Glazing Impact	IFET, Inc. - FL 33126	10/27/2025 01/22/2026 01/22/2026 02/16/2026	TR-IFET-25-0052 TR-IFET-25-0052.A TR-IFET-25-0052.B TR-IFET-25-0052.C	Arshad Viqar, P.E. FL PE# 38863
Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 201-94	Impact Test (Large Missile Impact)	IFET, Inc. - FL 33126	10/27/2025 01/22/2026 01/22/2026 02/16/2026	TR-IFET-25-0052 TR-IFET-25-0052.A TR-IFET-25-0052.B TR-IFET-25-0052.C	Arshad Viqar, P.E. FL PE# 38863
TAS 203-94	Cyclic Wind Pressure Load	IFET, Inc. - FL 33126	10/27/2025 01/22/2026 01/22/2026 02/16/2026	TR-IFET-25-0052 TR-IFET-25-0052.A TR-IFET-25-0052.B TR-IFET-25-0052.C	Arshad Viqar, P.E. FL PE# 38863


**PRODUCT EVALUATION REPORT**

- Florida Building Code - 9th Edition (2026) -
Per Rule 61G20-3 / Method 1 - (d)

FL #: **47930.1**DATE: **08/20/2026****Product Description**

Manufacturer: E.S. WINDOWS, LLC
Address: 3550 NW 49th St, Miami, FL 33142
Model Name: ES-FX1515AM / ES-SGD1515AM
Maximum Load: +102.0 PSF / -102.0 PSF (Large & Small Missile Impact)
Drawing No.: JA-1909-25, signed and sealed by Javad Ahmad, PE. - FL License No. 70592

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code - 9th Edition (2026 FBC).



Evaluation Report Engineer:

Javad Ahmad, PE

FL P.E.# 70592

EB C.A.N. # 34254

JAVAD AHMAD PE, Inc.

Sealed: 08/20/2026