

Evaluation Report Optifusion Fixed
February 12, 2026

Product Description: Optifusion Aluminum Fixed Window Wall and Fixed Windows

Manufacturer: Optimedia SRL, Calea Santandrei St. 38, Oradea 410238, Romania

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc. Trl., Camden, TN
- 2) Approval drawing Optifusion-Fixed, Rev. 0, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Report BW-OPT-25-008, from Blackwater Testing Lab, Altivole, Italy, with testing performed: TAS 201/202/203-94
- 4) Supplemental Calculations to support Optifusion-Fixed, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document Optifusion-Fixed.

Limitations of Use: This product:

- May be used in the configurations, design pressures, and sizes as indicated in Optifusion-Fixed
- Is large and small missile impact resistant and does not require the use of shutters
- May be used in the High Velocity Hurricane Zone
- Requires laminated glass as indicated in Optifusion-Fixed, with Kuraray Sentryglas interlayer per current Miami-Dade NOA. I have evaluated this interlayer material and find that it complies with the requirements of the 8th Ed. (2023) Florida Building Code for use in this product.
- Requires thermally broken aluminum framing as indicated in Optifusion-Fixed

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Optimedia or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2026.02.14
15:30:11 -06'00'

2/12/2026
Lucas A. Turner, P.E.
FL PE #58201