AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 47957
Date: 12/3/2025

Detailed Product Description:
Manufacturer: VIEWSCAPES
Manufacturer Address: VIA PADOVA, 14, 31041 CORNUDA TV, ITALY
Model Name: SERIES LUX THERMAL OUTSWING ENTRANCE DOOR
Maximum Load: +60.1, -60.1 PSF (Large Missile Impact)
Installation Drawings # 25-86F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ___ Yes ___X No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Blackwater Testing Lab	10/17/2025	BW-ROC-24-001	Roberto Archilla, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Blackwater Testing Lab	10/17/2025	BW-ROC-24-001	Roberto Archilla, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	Blackwater Testing Lab	10/17/2025	BW-ROC-24-001	Roberto Archilla, PE
AAMA 1304	Forced Entry Test	Blackwater Testing Lab	10/17/2025	BW-ROC-24-001	Roberto Archilla, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Blackwater Testing Lab	10/17/2025	BW-ROC-24-001	Roberto Archilla, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ LICENSE No. 81223 STATE OF FLORIDA PROFESSIONAL ENGINEER

Sealed: 12/15/2025