

Evaluation Report PL-FL0171-25
February 19, 2026

Product Description: 8'-0" Opaque I/S or O/S Single or Double Door w/ or w/out Sidelites

Manufacturer: Pella Corporation, Pella, IA

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code, including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) NAMI Certification No. NI016872.04
- 3) Approval drawing PL-FL0171-25, signed and sealed by Lucas A. Turner, P.E.
- 4) Testing as indicated in NI016872.04, with Specification: TAS 201/202/203, ASTM E330-14
- 5) Supplemental Calculations to support PL-FL0171-25, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document PL-FL0171-25.

Limitations of Use: This product:

- May be used in sizes and configurations, with panels and glazing, as indicated in PL-FL0171-25. IG impact glazing requires the use of Saflex PVB interlayer in accordance with Miami-Dade NOA 23-0713.18.
- Achieves design pressures and water ratings as indicated in first sheet of PL-FL0171-25
- May be used in the High Velocity Hurricane Zone (HVHZ)
- Is impact resistant and does not require the use of shutters in windborne debris regions
- Requires Fiberglass framing as indicated in testing and certifications listed above

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Pella or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2026.02.19
18:22:36 -06'00'

2/19/2026
Lucas A. Turner, P.E.
FL PE #58201