AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 48101
Date: 02/27/2026

Detailed Product Description:
Manufacturer: ALDORA ALUMINUM & GLASS PRODUCTS, INC.
Manufacturer Address: 4250 CORAL RIDGE DRIVE, SUITE 101, CORAL SPRINGS, FL 33065
Model Name: VISTA VIEW ALUMINUM HORIZONTAL SLIDING WINDOW
Maximum Load: +60 PSF, -65 PSF (Large Missile Impact)
Installation Drawings # 26-03F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used _X_ Yes __No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	IFET, Inc.	2/11/2026	TR-IFET-25-0093	Arshad Viqar, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	IFET, Inc.	2/11/2026	TR-IFET-25-0093	Arshad Viqar, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	IFET, Inc.	2/11/2026	TR-IFET-25-0093	Arshad Viqar, PE
ASTM F588	Forced Entry	IFET, Inc.	2/11/2026	TR-IFET-25-0093	Arshad Viqar, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 TAS 201 & 203	Large Missile Impact & Cyclic	IFET, Inc.	2/11/2026	TR-IFET-25-0093	Arshad Viqar, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ
LICENSE
No. 81223
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Sealed: 02/27/2026

9360 Sunset Drive Ste 220 | Miami, FL 33173 | T: 305.264.8100 | F: 305.262.6978 | www.afceng.com | alfarooq@afceng.com