

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION GLASS, INC.
4720 NW 15TH AVE. UNIT 4A
FORT LAUDERDALE, FL

PRODUCT
SERIES "450 TB"
ALUMINUM INTEGRAL WINDOW/ PTAC LOUVER SYSTEM
NON-IMPACT

TEST REPORT # ATLSF 0805.02-25

UNIT SIZE: 72" X 96"
DESIGN PRESSURE: (MAX.) = -75/+60 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS202-94, ASTM E283-04, ASTM E330-14 (2021), ASTM E331-00 (2016)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	REPORT DATE	ENGINEER
TAS202-94 ASTM E330-14	UNIFORM STATIC AIR PRESSURE	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0805.02-25	1/20/26	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94	AIR INFILTRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0805.02-25	1/20/26	STEPHEN WARTER, P.E. PE #: 54395
ASTM E331-00 & TAS 202	WATER PENETRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0805.02-25	1/20/26	STEPHEN WARTER, P.E. PE #: 54395

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2023/ 2026 FLORIDA BUILDING CODE

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION #32093
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431



Digitally signed by
Christopher Stanton
Date: 2026.10.14
05:58:48 -04'00'

