



1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

## Product Evaluation Report

*of*

**Eurocraft Industries, Inc.  
150 Series Fixed Window  
(HVHZ) (Impact)**

*for*

**Florida Product Approval**

**FL# FL48140**

**Report No. 9979**

### Current Florida Building Code

**Method:** 1-D (Engineering Evaluation)  
**Category:** Windows  
**Sub – Category:** Fixed

**Product:** 150 Series Fixed Window  
**Materials:** Aluminum 6063-T6  
**Product Dimensions:** See Installation Instructions, ECI044

### Prepared for:

**Eurocraft Industries, Inc.  
9251 NW 112th Ave.  
Medley, FL, 33178**


### Prepared by:

**Hermes F. Norero, P.E.**  
Florida Professional Engineer # 73778  
Date: 4/15/2026

### Contents:

Evaluation Report      Pages 1 – 3

Digitally signed by Hermes F. Norero, P.E.  
Reason: I am approving this document  
Date: 2026.04.15 18:36:12 -04'00'



Hermes F. Norero, P.E.  
Florida P.E. No. 73778

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

**Manufacturer:** Eurocraft Industries, Inc.

**Product Category:** Windows

**Product Sub-Category:** Fixed

**Compliance Method:** State Product Approval Method (1)(d)

**Product Name:** 150 Series Fixed Window  
(HVHZ) (Impact)

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Eurocraft Industries, Inc.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **ECI044**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

**Limits of Use:**

1. This product has been evaluated and is in compliance with the current Florida Building Code, **including** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with chapter 16 of the current edition of the Florida Building Code and **does not require** impact resistant covering in areas requiring Impact Resistance.
4. Site conditions that deviate from the details of installation instructions **ECI044** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **ECI044** for size and design pressure limitations.

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

**Quality Assurance Agency:** The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation and Management Institute**. (FBC Organization # QUA1789).

**Performance Standards:** The product described herein has been evaluated per:

- TAS 201-94
- TAS 202-94
- TAS 203-94
- ANSI Z97.1-14

**Referenced Data:**

1. Product Testing performed by **QAI Laboraotories Inc.** (FBC Organization # TST9808)  
Report #: Report Date:  
QA-5358a 03/20/26  
QA-5358b 03/20/26  
QA-5358c 03/20/26  
QA-5358d 03/20/26  
QA-5358e 03/20/26  
QA-5358f 04/14/26  
Signed and Sealed by Idalmis Ortega, P.E. FL# 76905
2. Quality Assurance Agency  
National Accreditation and Management Institute  
(FBC Organization # QUA1789)
3. Material Certification  
**Miami Dade County RER Notice Acceptance**  
Current NOA for PVB Interlayler by Kuraray America, Inc.

**Installation:**

Refer to Installation Instructions (**ECI044**) for anchor types, spacing, and more details of the installation requirements.

**Design Pressure:**

Refer to Installation Instructions (**ECI044**) for design pressure configurations.