



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 48167

Date: 4/13/2026

Detailed Product Description:

Manufacturer: PEETZ WINDOWS AND DOORS

Manufacturer Address: 15951 S.W. 41 STREET, SUITE 150, WESTON, FLORIDA

Model Name: OUTSWING GLAZED WOOD DOOR

Maximum Load: +70 PSF, -70 PSF (Large Missile Impact)

Installation Drawings # 26-09F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Intertek	3/25/2026	S4675.01-450-18	Tanya Dolby, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Intertek	3/25/2026	S4675.01-450-18	Tanya Dolby, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Intertek	3/25/2026	S4675.01-450-18	Tanya Dolby, P.E.
AAMA 1304	Forced Entry	Intertek	3/25/2026	S4675.01-450-18	Tanya Dolby, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Intertek	3/25/2026	S4675.01-450-18	Tanya Dolby, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq

PE # 81223

Al-Farooq Corporation

EB # 3538



Sealed: 04/16/2026