Engineering Evaluation Report

Prepared by:
A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: 29296

Manufacturer:
Anlin Industries
1665 Tollhouse Rd
Clovis, CA 93611

Product Description:
Coronado Series Non-Impact Resistant, Vinyl Picture Window (NI), FL48193

Compliance:
The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance by Rule 61 G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:
1. Approval Document: Drawing number PWFPA-1, signed, and sealed by A. Lynn Miller, P.E.
2. Test Reports:
C2953.01-301-44, D1245.01-301-44, E1685.01-301-44, H2671.01-301-44
Architectural Testing, Inc (Intertek B&C), Fresno, CA
AAMA/WDMA/CSA 101/I.S.2/A440-2011

H2671.01-301-44
Architectural Testing, Inc (Intertek B&C), Fresno, CA
AAMA/WDMA/CSA 101/I.S.2/A440-2017

Limitations and Conditions of use:
• Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
• This product is not rated to be used in the HVHZ.
• This product is not impact resistant and does require impact protection in wind borne debris regions.
• Frame and sash material to be extruded vinyl.
• Units must be installed in accordance with Approval Documents.

Certification of Independence:
A. Lynn Miller, P.E., is employed by MITER Brands and therefore has a financial interest in the company or any company manufacturing or distributing products for which this report is being issued, but does not, nor will acquire a financial interest in any other entity involved in the approval process of this product.