



PRODUCT EVALUATION REPORT

- Florida Building Code - 9th Edition (2026) -

Per Rule 61G20-3 / Method 1 - D

FL #: **48202**

DATE: 08/20/2026

Product Description

Manufacturer: EVENTSTAR STRUCTURES CORP.
Address: 8100 NW 90th St, Medley, FL 33166
Model Name: TENSA VINYL BUILDING ATTACHED ROOFING / CANOPY STRUCTURE
Maximum Load: +95 PSF / -95 PSF (Large & Small Missile Impact)
Drawing No.: JA-1613-25, signed and sealed by Javad Ahmad, PE. - FL License No. 70592

This product COMPLIES with the 2026 FBC, 9th Edition, for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/TAS 202/TAS 203.

For maximum sizes and anchor type refer to installation drawings.

Comparative Analysis used: ☐ YES ☒ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
Tensile Test	1" Heat Welded Keder Tensile Strength Test	Hurricane Engineering & Testing Inc. (FL, 33178)	09/09/2024	HETI-24-A992	Dr. Ram N. Tewari, Ph.D., PE
Tensile Test	2" Heat Welded Keder Tensile Strength Test	Hurricane Engineering & Testing Inc. (FL, 33178)	09/09/2024	HETI-24-A993	Dr. Ram N. Tewari, Ph.D., PE
Tensile Test	1" Heat Welded Keder Tensile Strength Test	Hurricane Engineering & Testing Inc. (FL, 33178)	09/09/2024	HETI-24-A994	Dr. Ram N. Tewari, Ph.D., PE
Tensile Test	2" Heat Welded Keder Tensile Strength Test	Hurricane Engineering & Testing Inc. (FL, 33178)	09/09/2024	HETI-24-A995	Dr. Ram N. Tewari, Ph.D., PE
ASTM E283/E283M-19	Air Infiltration Leakage	IFET, Inc. - FL 33126	11/04/2025	TR-IFET-25-0048.R1	Arshad Viqar, P.E. FL PE# 38863
TAS 202-94	Uniform Static Test	IFET, Inc. - FL 33126	11/04/2025	TR-IFET-25-0048.R1	Arshad Viqar, P.E. FL PE# 38863
ASTM E331-00	Water Penetration by Static Air Pressure Dif.	IFET, Inc. - FL 33126	11/04/2025	TR-IFET-25-0048.R1	Arshad Viqar, P.E. FL PE# 38863
Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 201-94	Impact Test (Large Missile Impact)	IFET, Inc. - FL 33126	11/04/2025	TR-IFET-25-0048.R1	Arshad Viqar, P.E. FL PE# 38863
TAS 203-94	Cyclic Wind Pressure Load	IFET, Inc. - FL 33126	11/04/2025	TR-IFET-25-0048.R1	Arshad Viqar, P.E. FL PE# 38863

7320 NW 58TH STREET. MIAMI, FL 33166



PRODUCT EVALUATION REPORT

- Florida Building Code - 9th Edition (2026) -

Per Rule 61G20-3 / Method 1 - D

FL #: **48202**

DATE: **08/20/2026**

Product Description

Manufacturer: EVENTSTAR STRUCTURES CORP.
Address: 8100 NW 90th St, Medley, FL 33166
Model Name: TENSA VINYL BUILDING ATTACHED ROOFING / CANOPY STRUCTURE
Maximum Load: +95 PSF / -95 PSF (Large & Small Missile Impact)
Drawing No.: JA-1613-25, signed and sealed by Javad Ahmad, PE. - FL License No. 70592

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 FBC, 9th Edition.



Sealed: 08/20/2026

Evaluation Report Engineer:

Javad Ahmad, PE

FL P.E.# 70592

EB C.A.N. # 34254

JAVAD AHMAD PE, Inc.