

L. Roberto Lomas P.E.

208 7th Ave.

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515656

Manufacturer: NT Window, Inc.
2900 West Seminary Dr.
Fort Worth, TX 76133

Product Line: A100 PVC Awning Window - Non-Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04216, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: E2796.02-801-44 signed by Andy Cost
Architectural Testing Inc., Southlake, TX.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 50.13 psf (48" x 32" Fin)
Water penetration resistance 7.52psf
3. Test report No.: D1160.02-801-44 signed by Andy Cost
Architectural Testing Inc., Southlake, TX.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 50.13 psf (48" x 32" Finless)
4. Anchor calculations, report number 515656-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 50 psf
- Unit size: 48" x 32"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded Rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04216.

When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

