Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

PRODUCT EVALUATION REPORT	
Project No.: ACE-2026-138	**Report No.:** PER-ACE-1207, Rev. 0

Product Description:

- Series 1310 & 2010 Vinyl XX Outswing Casement Window, Non-Impact
- Series 1320 & 2020 Vinyl XOX Outswing Casement Window, Non-Impact

Product Manufacturer: Regency Plus, Inc., 2000 Locust Gap Highway, Mt. Carmel. PA 17850

Code Compliance Statement: This report evaluates the fenestration product(s) listed above to the requirements of FAC Product Approval Rule 61G20-3.005. This product complies with the requirements of the 8th Edition (2023) Florida Building Code excluding the High Velocity Hurricane Zone (HVHZ) per the product testing standards listed below.

Compliance Method: Product Approval Rule 61G20-3.005(1)(a) – Certification Mark or Listing

Documentation:

1. Installation Drawings
    a. Drawing No. RPLS0090-FPAS, Rev. 0, Series 1310 & 2010 Vinyl XX Outswing Casement Window, Non-Impact, signed and sealed by Robert J. Amoruso, PE.
        i. This drawing is in conformance with the 8th Edition (2023) Florida Building Code excluding the High Velocity Hurricane Zone (HVHZ).
    b. Drawing No. RPLS0091-FPAS, Rev. 0, Series 1320 & 2020 Vinyl XOX Outswing Casement Window, Non-Impact signed and sealed by Robert J. Amoruso, PE.
        i. This drawing is in conformance with the 8th Edition (2023) Florida Building Code excluding the High Velocity Hurricane Zone (HVHZ).
2. Test Reports by Molima, LLC, 1410 Eden Road, York, PA 17402
    a. Series 1310 & 2010 Vinyl XX Outswing Casement Window, Non-Impact
        i. AAMA/WDMA/CSA 101/I.S.2/A440-2022/2017. T Test Report No. 33054.01-106-11, dated 6/16/26 for Series 1310 XX Casement with annealed glazing.
        ii. AAMA/WDMA/CSA 101/I.S.2/A440-2022/2017. Test Report No. 33053.01-106-11, dated 6/16/26 for Series 2010 XX Casement with tempered glazing.
    b. Series 1320 & 2020 Vinyl XOX Outswing Casement Window, Non-Impact
        i. AAMA/WDMA/CSA 101/I.S.2/A440-2022/2017. Test Report No. 33056.01-106-11, dated 6/16/26 for Series 1320 XOX Casement with annealed glazing.
        ii. AAMA/WDMA/CSA 101/I.S.2/A440-2022/2017. Test Report No. 33055.01-106-11, dated 6/16/26 for Series 2020 XOX Casement with tempered glazing.
3. Calculations in support of installation requirements for Reference 1 drawings, signed and sealed by Robert J. Amoruso, PE.
4. Glass meets the requirements of ASTM E1300-16.

Installation: Fenestration units shall be installed according to Reference 1 installation drawings.

Component Certification:

- Extruded Rigid PVC by Vision Extrusions Group Limited per current Miami-Dade NOA.

Limitations & Conditions of Use:

- Shall be used in the configurations and product sizes as indicated in Reference 1 installation drawings.
- This product may NOT be used in the High Velocity Hurricane Zone.
- This product has NOT been tested with impact resistant glazing.
    - When used in wind borne debris regions, additional impact protective devices are required.
- Site conditions not covered in this product evaluation document are subject to additional engineering analysis by a licensed professional engineer or registered architect as required by the authority having jurisdiction.
- Adequacy of the existing structural substrates as a main wind force resisting system capable of withstanding and transferring applied product loads to the foundation is the responsibility of the licensed professional engineer or registered architect acting as the design professional of record for the project of installation.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.
Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed by Robert J Amoruso
Date: 2026.07.17 11:03:07 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752