BUILDING DROPS
1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of

Euro-Wall, LLC
MS-Multislide System
(WZ3) (Impact)

for

Florida Product Approval

FL# FL48363

Report No. 11923

Current Florida Building Code

Method:	**1 – D (Engineering Evaluation)**
Category:	**Exterior Doors**
Sub – Category:	**Sliding Exterior Door Assemblies**
Product:	**MS-Multislide System**
Materials:	**Aluminum 6063-T5**
Product Dimensions:	**See Installation Instructions, EWS060**

Prepared for:
Euro-Wall, LLC
P.O. Box 8007,
North Port, FL 34290

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer #73778
Date: 10/20/2026

HERMES F. NORERO LICENSE No. 73778 STATE OF FLORIDA PROFESSIONAL ENGINEER

Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.10.21 11:51:06 -04'00'

Hermes F. Norero, P.E.
Florida No. 73778

Manufacturer: **Euro-Wall, LLC**

Product Category: Exterior Doors

Product Sub-Category: Sliding Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: **MS-Multislide System (WZ3) (Impact)**

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL #73778) for **Euro-Wall, LLC** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **EWS060**, signed and sealed by Hermes F. Norero, P.E. (FL #73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not require** an impact resistant covering in Wind Zone 3 or less.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering in Wind Zone 4.
5. Site conditions that deviate from the details of installation instructions **EWS060** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **EWS060** for size and design pressure limitations.

954.399.8478 954.744.4738
BUILDINGDROPS.COM CONTACT@BUILDINGDROPS.COM

Quality Assurance:

The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation and Management Institute.**
(FBC Organization #QUA1789)

Performance Standards:

The product described herein has been evaluated per:

- TAS 201-94
- TAS 202-94
- TAS 203-94
- ASTM E1886-19
- ASTM E1996-23
- AAMA/WDMA/CSA 101/I.S.2/A440-22

Referenced Data:

1. Product Testing performed by **Blackwater Technical Services Inc.**
   (FBC Organization #TST10394)
   Report #: BT-EUW-19-001 Report Date: 09/12/2019
   TAS report signed and sealed by Constantin Bortes, FL P.E. No. 77915

   Report #: BT-EUW-20-003 Report Date: 12/17/2020
   Report #: BT-EUW-20-003B Report Date: 02/03/2021
   Report #: BT-EUW-22-001 Report Date: 06/30/2023
   TAS reports signed and sealed by Michael D. Caldwell, FL P.E. No. 49979

2. Product Testing performed by **IFET Inc.**
   (FBC Organization #TST14775)
   Report #: TR-IFET-25-0011 Report Date: 04/16/2025

3. Product Testing performed by **Molimo LLC**
   (FBC Organization #TST11282)
   Report #: 33875.01 Report Date: 10/23/2026
   Report #: 33875.02 Report Date: 10/23/2026
   Report #: 33875.03 Report Date: 10/23/2026

954.399.8478 954.744.4738
BUILDINGDROPS.COM CONTACT@BUILDINGDROPS.COM

Installation:

Refer to Installation Instructions (**EWS060**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**EWS060**) for design pressures based on size, configuration, and glass types.

954.399.8478
954.744.4738
BUILDINGDROPS.COM
CONTACT@BUILDINGDROPS.COM