



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 48365

Date: 8/11/2026

Detailed Product Description:

Manufacturer: HOPE'S WINDOWS, INC.

Manufacturer Address: 84 HOPKINS AVE, P.O. BOX 580 JAMESTOWN, NY 14701

Model Name: SS30 STEEL FIXED WINDOW

Maximum Load: +80 PSF, -80 PSF (Large Missile Impact)

Installation Drawings # 25-75F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, loads and anchor type refer to installation drawings.

Comparative analysis used ☒ Yes ☐ No

Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Element Materials Technology	05/22/2014	ESP016682P-1556.2	Thomas A. Kolden, PE
		Intertek	03/06/2024	Q8375.01-201-18	Tanya Dolby, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Element Materials Technology	05/22/2014	ESP016682P-1556.2	Thomas A. Kolden, PE
		Intertek	03/06/2024	Q8375.01-201-18	Tanya Dolby, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	Element Materials Technology	05/22/2014	ESP016682P-1556.2	Thomas A. Kolden, PE
		Intertek	03/06/2024	Q8375.01-201-18	Tanya Dolby, PE
		Molimo	07/22/2025	31163.01-106-11	Michael D. Stremmel, PE
ASTM F588	Forced Entry	Element Materials Technology	05/22/2014	ESP016682P-1556.2	Thomas A. Kolden, PE
		Intertek	03/06/2024	Q8375.01-201-18	Tanya Dolby, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)


TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 TAS 201 & 203 ASTM E1886/1996	Large Missile Impact & Cyclic Level D & E	Element Materials Technology	05/22/2014	ESP016682P-1556.2	Thomas A. Kolden, PE
		Intertek	03/06/2024	Q8375.01-201-18	Tanya Dolby, PE
		Molimo	07/22/2025	31163.01-106-11	Michael D. Stremmel, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 8/11/2026