



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 48384

Date: 8/17/2026

Detailed Product Description:

Manufacturer: KOMMERLING USA, INC.

Manufacturer Address: 3415-A STANWOOD BLVD. HUNTSVILLE, AL 35811

Model Name: SERIES 76MD TILT & TURN PVC WINDOW

Maximum Load: +50.1 PSF, -75.0 PSF (Non-Impact)

Installation Drawings # 26-13F

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA 101/I.S.2/A440/NAFS)

Test	Description	Test Location	Test Report Date	Test Report #
ASTM E283	Air Infiltration Leakage	PRI Construction Materials Technologies	12/8/2025	2569T0018
ASTM E331 & ASTM E547	Water Penetration	PRI Construction Materials Technologies	12/8/2025	2569T0018
ASTM E330	Uniform Static Air Press.	PRI Construction Materials Technologies	12/8/2025	2569T0018
ASTM F588	Forced Entry Test	PRI Construction Materials Technologies	12/8/2025	2569T0018

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 8/18/2026