



PRODUCT EVALUATION REPORT

- Florida Building Code - 9th Edition (2026) -
Per Rule 61G20-3 / Method 1 - (d)

FL #: **48398.1**

DATE: **08/20/2026**

Product Description

Manufacturer: E.S. WINDOWS, LLC
Address: 3550 NW 49th St, Miami, FL 33142
Model Name: Series ES-9000 Aluminum Inswing Door (Large Missile Impact - Level E)
Maximum Load: +120.0 PSF / -130.0 PSF
Drawing No.: JA-1595-26, signed and sealed by Javad Ahmad, PE. - FL License No. 70592


This product COMPLIES with the 2026 Florida Building Code - 9th Edition (2026 FBC) for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/202/203.

For maximum sizes and anchor type refer to installation drawings.

Comparative Analysis used: ☒ YES ☐ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
ASTM E283	Air Infiltration Leakage	IFET, Inc.	08/19/2026	TR-IFET-25-0112	Arshad Viqar, P.E.
AAMA 1304	Forced Entry Test	IFET, Inc.	08/19/2026	TR-IFET-25-0112	Arshad Viqar, P.E.
Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 201-94	Impact Test (Large Missile Impact / Level E)	IFET, Inc.	08/19/2026	TR-IFET-25-0112	Arshad Viqar, P.E.
TAS 203-94	Cyclic Wind Pressure Load	IFET, Inc.	08/19/2026	TR-IFET-25-0112	Arshad Viqar, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 FBC, 9th Edition.



Evaluation Report Engineer:

Javad Ahmad, PE

FL P.E.# 70592

EB C.A.N. # 34254

JAVAD AHMAD PE, Inc.

Sealed: 08/20/2026