

**PRODUCT EVALUATION REPORT**

- Florida Building Code - 9th Edition (2026) -
Per Rule 61G20-3 / Method 1 - (d)

FL #: **48401.1**DATE: **08/20/2026****Product Description**

Manufacturer: E.S. WINDOWS, LLC
Address: 3550 NW 49th St, Miami, FL 33142
Model Name: Series ES-GD3020 Aluminum Sectional Garage Door (Large Missile Impact)
Maximum Load: +105.0 PSF / -126.0 PSF
Drawing No.: JA-1594-26, signed and sealed by Javad Ahmad, PE. - FL License No. 70592

This product COMPLIES with the 2026 Florida Building Code - 9th Edition (2026 FBC) for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/202/203.

For maximum sizes and anchor type refer to installation drawings.

Comparative Analysis used: ☒ YES ☐ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 202-94	Uniform Static Test	IFET, Inc. - FL 33126	08/18/2026	TR-IFET-25-0086	Arshad Viqar, P.E. FL PE# 38863
Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 201-94	Impact Test (Large Missile Impact)	IFET, Inc. - FL 33126	08/18/2026	TR-IFET-25-0086	Arshad Viqar, P.E. FL PE# 38863
TAS 203-94	Cyclic Wind Pressure Load	IFET, Inc. - FL 33126	08/18/2026	TR-IFET-25-0086	Arshad Viqar, P.E. FL PE# 38863

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code - 9th Edition (2026 FBC).



Evaluation Report Engineer:

Javad Ahmad, PE

FL P.E.# 70592

EB C.A.N. # 34254

JAVAD AHMAD PE, Inc.

Sealed: 08/20/2026