



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 48407

Date: 08/19/2026

Detailed Product Description:

Manufacturer: BROMBAL ITALY

Manufacturer Address: VIA VALLÀ, 24, CASELLE DI ATIVOLE, ITALY 31030

Model Name: CUSTOM PROFILE STEEL/STAINLESS STEEL FIXED WINDOW

Maximum Load: +46 PSF, -52 PSF (Large Missile Impact)

Installation Drawings # 26-21F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS 202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Blackwater Testing Lab	05/02/2026	BW-BRO-26-002-001	Roberto Archila, PE
ASTM E331 or ASTM 547 & TAS 202	Water Penetration	Blackwater Testing Lab	05/02/2026	BW-BRO-26-002-001	Roberto Archila, PE
ASTM E330 & TAS 202	Uniform Static Air Pressure	Blackwater Testing Lab	05/02/2026	BW-BRO-26-002-001	Roberto Archila, PE
ASTM F588	Forced Entry	Blackwater Testing Lab	05/02/2026	BW-BRO-26-002-001	Roberto Archila, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 (TAS 201 & 203) ANSI Z97.1	Large Missile Impact & Cyclic	Blackwater Testing Lab	05/02/2026	BW-BRO-26-002-001	Roberto Archila, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 8/20/2026