

Product Evaluation Report

of

**Pella Corporation
Outswing Hinged Doors
(Non-HVHZ) (Non-Impact)**

for

Florida Product Approval

FL# FL48408

Report No. 10864

Current Florida Building Code

Method:	1 – A (Certificate)
Category:	Exterior Doors
Sub – Category:	Swinging Exterior Door Assemblies
Product:	Outswing Hinged Doors (Non-HVHZ) (Non-Impact)
Materials:	Wood
Product Dimensions:	See Installation Instructions, PLA007

Prepared for:

**Pella Corporation
102 Main St.,
Pella, IL 50219**

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer #73778

Date: 8/24/2026

Contents:

Evaluation Report

Pages 1 – 4



Manufacturer: Pella Corporation

Product Category: Exterior Doors

Product Sub-Category: Swinging Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(a)

Product Name: Outswing Hinged Doors
(Non-HVHZ) (Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL #73778) for **Pella Corporation** based on Method 1a of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **PLA007**, signed and sealed by Hermes F. Norero, P.E. (FL #73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering in areas that require impact resistance.
4. Site conditions that deviate from the details of installation instructions **PLA007** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **PLA007** for size and design pressure limitations.

Certification Agency: The manufacturer has demonstrated compliance of manufacture of products in accordance with the Florida Building Code for manufacturing under an approved certification agency through **Window and Door Manufacturer Association** (FBC Organization #CER1508)

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-22

Referenced Data:

- Product Testing performed by **Element Materials Technology** (FBC Organization # TST9610)

Report:	Date:
PUS23000750.1	04/20/2026
PUS23000750.2	04/26/2026
PUS23000750.4Rev	07/11/2026
PUS23000750.5Rev	07/11/2026
PUS23000750.8A	04/27/2026
PUS23000750.8B	04/27/2026
PUS23000750.11	04/30/2026
PUS23000750.12	05/02/2026
PUS23000750.13	05/02/2026
PUS23000750.14	05/02/2026
PUS23000750.15A	05/05/2026
PUS23000750.15B	05/05/2026
PUS23000750.18A	05/09/2026
PUS23000750.18B	05/09/2026
PUS23000750.19Rev	07/11/2026
PUS23000750.20	05/09/2026
PUS23000750.21	05/05/2026
PUS23000750.3	04/26/2026
PUS23000750.6Rev	07/11/2026
PUS23000750.7Rev	07/11/2026
PUS23000750.9	04/27/2026
PUS23000750.10Rev	07/14/2026
PUS23000750.16Rev	07/14/2026
PUS23000750.17	05/09/2026

2. Certification Agency
Window and Door Manufacturer Association
(FBC Organization #CER1508)

Installation:

Refer to Installation Instructions (**PLA007**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**PLA007**) for design pressures based on size, configuration, and glass types.