

PRODUCT EVALUATION REPORT	
Project No.: ACE-2026-103	Report No.: ACE-PER-1215

Product Description:

- Series 6200i Vinyl Horizontal Sliding Window (XOX, QHQ) – HVHZ – Impact
- Series 6200i Vinyl Horizontal Sliding Window (XOX, Eq. Lite) – HVHZ – Impact
- Series 6200i Vinyl Horizontal Sliding Window (XX, Eq. Lite) – HVHZ – Impact

Product Manufacturer: Vytex Windows, 9425 Washington Blvd. N., Laurel, MD 20723

Code Compliance Statement: This report evaluates the product(s) listed above to the requirements of FAC Product Approval Rule 61G20-3.005. This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone (HVHZ) per the product testing standards listed below.

Compliance Method: 61G20-3.005(1)(a) – Certification Mark or Listing

Documentation/References:

1. Installation Drawing No. VYTEX005, first issue, signed and sealed by Robert J. Amoruso, PE for Series 6200i Vinyl Horizontal Sliding Window (XOX, QHQ) – HVHZ – Impact
 - a. This drawing is in conformance with the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone (HVHZ)
 - b. Performance Testing Based on the following.
 - i. Molimo Test Report No. 31840.01-106-11-R1, dated 7/31/26, 6200i Horizontal Sliding Window (XOX, QHQ)
 1. Performance Standards
 - a. TAS 201-94
 - b. TAS 202-94
 - c. TAS 203-94
 2. Size and Results
 - a. +/- 55 psf DP
 - b. 110" x 63"
2. Installation Drawing No. VYTEX006, first issue, signed and sealed by Robert J. Amoruso, PE for Series 6200i Vinyl Horizontal Sliding Window (XOX, Equal) – HVHZ – Impact
 - c. This drawing is in conformance with the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone (HVHZ)
 - d. Performance Testing Based on the following.
 - i. Molimo Test Report No. 31838.01-106-11-R1, dated 7/31/26, 6200i Horizontal Sliding Window (XOX, Equal)
 1. Performance Standards
 - a. TAS 201-94
 - b. TAS 202-94
 - c. TAS 203-94
 2. Size and Results
 - a. +/- 55 psf DP
 - b. 110" x 63"

3. Installation Drawing No. VYTEX007, first issue, signed and sealed by Robert J. Amoruso, PE for Series 6200i Vinyl Horizontal Sliding Window (XOX, Equal) – HVHZ – Impact
 - e. This drawing is in conformance with the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone (HVHZ)
 - f. Performance Testing Based on the following.
 - i. Molimo Test Report No. 31836.01-106-11-R1, dated 7/31/26, 6200i Horizontal Sliding Window (XX, Equal)
 1. Performance Standards
 - a. TAS 201-94
 - b. TAS 202-94
 - c. TAS 203-94
 2. Size and Results
 - a. +/- 55 psf DP
 - b. 73" x 63"
2. Installation Anchorage Calculation
 - a. No. ACE-CALC-1215, 6200i Horizontal Sliding Window


Limitations & Conditions of Use:

- This product has been evaluated for use inside the High Velocity Hurricane Zone (HVHZ).
- This product has been tested for impact resistance.
- Refer to Product Installation Instructions noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to substrate structure.
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.
- Site wind pressures shall be determined by a licensed professional engineer in accordance with the current edition of the Florida Building Code (and/or ASCE 7 as referenced in the current edition of the Florida Building Code) for components and cladding based on allowable stress design.
- Site conditions not covered in this product evaluation document are subject to additional engineering analysis by a licensed professional engineer or registered architect as required by the authority having jurisdiction.
- Adequacy of the existing structural substrates as a main wind force resisting system capable of withstanding and transferring applied product loads to the foundation is the responsibility of the licensed professional engineer or registered architect acting as the design professional of record for the project of installation.

**Certificate of Independence per Product
Approval Rule 61G20-3.009**

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso
Date:
2026.10.06
11:02:35[®]
-04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752