

Evaluation Report IN0066-R14
April 18, 2025

Product Description: Double Hung Window Series 07-09/10/20, X/X configuration

Manufacturer: Simonton Windows, 1 Cochrane Ave., Pennsboro, WV

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Installation drawing IN0066-R14, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports A9235.01-501-47, C3513.01-109-47, C5631.01-109-47, C7745.01-109-47, C9037.01-501-47, D0294.01-501-47 and D0296.01-501-4, by Architectural Testing, Inc., and NCTL-110-26198-1, by National Certified Testing Laboratories, with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-11/17
- 4) Supplemental Calculations to support IN0066-R14, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to installation drawing IN0066-R14.

Limitations of Use: This product:

- May be used in the configurations and product sizes as indicated in IN0066-R14
- Is non-impact and requires the use of impact protective devices in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires white PVC extrusions in accordance with the product testing, IN0066-R14, and with current listing as an AAMA Certified Profile Licensee under AAMA 303

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Simonton Windows or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner, PE
58201
2025.04.18
13:03:25 -05'00'

4/18/2025
Lucas A. Turner, P.E.
FL PE #58201