

**Evaluation Report IN0368-R7**  
January 9, 2025

**Product Description:** Awning Window Series 08-09/08-10/08-20, X configuration

**Manufacturer:** Simonton Windows, 1 Cochrane Ave., Pennsboro, WV

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule 61G20-3.005 (4). This product complies with the requirements of the 8<sup>th</sup> Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

**Technical Documentation:**


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Installation drawing IN0368-R7, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports B2264.01-501-47-R0 and D0957.01-501-47-R0, from Architectural Testing, Inc., Springdale and York, PA, with testing performed with equivalency to:  
AAMA/WDMA/CSA 101/I.S.2/A440-08/11, ASTM E1886-19, and ASTM E1996-17
- 4) Supplemental Calculations to support IN0368-R7, signed and sealed by Lucas A. Turner, P.E.

**Installation:** Units must be installed according to installation drawing IN0368-R7.

**Limitations of Use:** This product:

- May be used in the configuration, DP, product size, and with glazing as indicated in IN0368-R7
- Is large missile impact resistant (missile level D, wind zone 4) and does not require the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires white SimEx, Inc. PVC extrusions with current listing as an AAMA Certified Profile Licensee under AAMA 303

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Simonton Windows or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



1/9/2025  
Lucas A. Turner, P.E.  
FL PE #58201